



Summary Report

Cable Certification

Cable ID	Result	Limit	Length(ft)	Margin	Date / Time
A-002	Pass	TIA - Cat 6 Channel	109.7	1.8 dB (NEXT)	1/21/2019 2:54:10 AM
A35-A-02	Pass	TIA - Cat 6 Channel	96.3	1.7 dB (NEXT)	1/21/2019 3:02:39 AM
A-001	Pass	TIA - Cat 6 Channel	110.2	0.8 dB (NEXT)	1/21/2019 2:12:53 AM
A-003	Pass	TIA - Cat 6 Channel	96.3	1.7 dB (NEXT)	1/21/2019 2:55:56 AM
A35-A-03	Pass	TIA - Cat 6 Channel	95.2	1.2 dB (NEXT)	1/21/2019 3:05:05 AM
A35-A-04	Pass	TIA - Cat 6 Channel	113.4	1.2 dB (NEXT)	1/21/2019 3:05:47 AM
A35-A-05	Pass	TIA - Cat 6 Channel	96.6	1.8 dB (NEXT)	1/21/2019 3:42:57 AM
A35-A-01	Pass	TIA - Cat 6 Channel	96.6	1.7 dB (NEXT)	1/21/2019 2:57:55 AM

Total
Records : 8
Total : 814.3ft
Length

Fiber Certification

Cable ID	Result	Limit	Length(ft)	Margin	Date / Time
MM-46-A-03	Pass	Loss Budget	39.4	2.5 dB	1/22/2019 5:10:39 AM
MM-46-A-01	Pass	Loss Budget	39.4	2.6 dB	1/22/2019 4:58:22 AM
A-001	Pass	Loss Budget	39.4	2.6 dB	1/22/2019 4:56:19 AM
MM-46-A-04	Pass	Loss Budget	39.4	2.5 dB	1/22/2019 5:10:56 AM
MM-46-A-02	Pass	Loss Budget	39.4	2.6 dB	1/22/2019 4:58:33 AM
MM-46-A-07	Pass	Loss Budget	39.4	2.7 dB	1/22/2019 5:12:50 AM
MM-46-A-05	Pass	Loss Budget	0	3.0 dB	1/22/2019 5:12:09 AM
MM-46-A-06	Pass	Loss Budget	39.4	2.7 dB	1/22/2019 5:12:38 AM
SM 1	Pass	Certification	34.4	∞ dB	1/31/2019 3:29:54 AM
SM 2	Pass	Certification	41	0.0 dB	1/31/2019 3:34:06 AM
SM 3	Pass	Certification	41	0.0 dB	1/31/2019 3:36:14 AM
A-002	Pass	Loss Budget	39.4	2.6 dB	1/22/2019 4:56:45 AM

Total
Records : 12
Total : 431.4ft
Length

Validation

Cable ID	Result	Limit	Length(ft)	Margin	Date / Time
A-001	Pass	IEEE 802.3	91.9	3.1dB	1/21/2019 2:16:19 AM
A-002	Pass	IEEE 802.3	173.9	1.7dB	1/21/2019 2:52:44 AM
Multi-Gig	Pass	IEEE 802.3	173.9	0.3dB	1/21/2019 2:49:02 AM

Total
Records : 3
Total : 439.6ft
Length